


# Gas System Status Report

## Rome


- UGPS qualification
- Control Electronics production schedule
- Gas circuit testing
- Software commands and safety
- Report from MIT

# Gas Circuit



B. Borgia  
TIM April 2006

# Control Electronics




B. Borgia  
TIM April 2006



# UGPS qualification


- UGPS cards located on TRD gas manifolds with preamps for differential pressure ( $\Delta p$ ) signals at manifold input/output
- Qualification tests:
  - TVT
  - Vibration
  - EMC
- All test passed, preliminary data report

|          |        |
|----------|--------|
| ce Phase | Return |
|----------|--------|




*B. Borgia*  
*TIM April 2006*

# UGPS-QM TVT




cold plate



T sensor


# Actual T profile



B. Borgia  
TIM April 2006

# TVT

## Output voltage




B. Borgia  
TIM April 2006

# EMC tests




Fig. 3: Conducted Emissions, DC Power Leads, Switching Spikes (CE07).



B. Borgia  
TIM April 2006

# Radiated Emission





UNIVERSITA' DEGLI STUDI DI PERUGIA  
POLO SCIENTIFICO E DIDATTICO DI TERNI  
Facoltà di Ingegneria  
Laboratorio di Caratterizzazione Elettromagnetica

# TEST REPORT

N° 061, Rev. 0

| Equipment Under Test (EUT) |      |
|----------------------------|------|
| UGPS QM                    |      |
| P.N.                       | S.N. |
| 28303101A121A01            | 100  |
| 28303101A121A01            | 101  |
| 28303101A122A01            | 100  |
| 28303101A122A01            | 101  |

Required by  
**G&A Engineering**  
Località Miele 100, Oricola (AQ) - 67063 Italy

## OBJECT

| TEST                                                               | STANDARD              |
|--------------------------------------------------------------------|-----------------------|
| Conducted Emissions, Power Leads, 30 Hz - 15 kHz                   | SSP 30237 Rev. F CE01 |
| Conducted Emissions, DC Power Leads, 10 kHz - 50 MHz               | SSP 30237 Rev. F CE02 |
| Conducted Emissions, DC Power Leads, Switching Spikes, Time Domain | SSP 30237 Rev. F CE07 |
| Conducted Susceptibility, AC Power Leads, 30 Hz - 50 kHz           | SSP 30237 Rev. F CS01 |
| Conducted Susceptibility, AC Power Leads, 50 kHz - 50 MHz          | SSP 30237 Rev. F CS02 |
| Conducted Susceptibility, Spikes, DC Power Leads                   | SSP 30237 Rev. F CS06 |
| Radiated Emissions, Electric Field, 14 kHz - 20 GHz                | SSP 30237 Rev. F RE02 |
| Radiated Susceptibility, Magnetic Induction Field                  | SSP 30237 Rev. F RS02 |
| Radiated Susceptibility, Electric Field, 10 kHz - 18 GHz           | SSP 30237 Rev. F RS03 |


Terni, 19 April 2006

Test Report issued by:  
Ing. Antonio Faba

Approved by:  
Prof. Ing. Ermanno Cardelli



Polo Scientifico e Didattico di Terni - Facoltà di Ingegneria  
Via Pentima Bassa 21, 05100 Terni - Tel. +39 0744/492912 - Fax. +39 0744/492925  
Pag.1 di 23



# ELECTROMAGNETIC COMPATIBILITY TEST REPORT

N° 061  
Rev. 0  
Date 19 April 2006

EUT:  
**UGPS QM**  
P.N. 28303101A121A01 S.N. 100 + 101  
P.N. 28303101A122A01 S.N. 100 + 101

Test Date  
3 + 7 April 2006

## 12. CONCLUSIONS

From 3 up to 7 April 2006 with the Laboratory of Electromagnetic Characterization of the "Polo Scientifico e Didattico di Terni", University of Perugia, Faculty of Engineering, Via Pentima Bassa 21, 05100 Terni, have been performed the EMC Tests on the equipment:

UGPS QM  
P.N. 28303101A121A01 S.N. 100  
P.N. 28303101A121A01 S.N. 101  
P.N. 28303101A122A01 S.N. 100  
P.N. 28303101A122A01 S.N. 101

produced by

G&A Engineering  
Località Miele 100, Oricola (AQ) - 67063 Italy

The results obtained in the emissions and susceptibility tests are in the following table:

| TEST                                                               | STANDARD              | TEST RESULT |
|--------------------------------------------------------------------|-----------------------|-------------|
| Conducted Emissions, Power Leads, 30 Hz - 15 kHz                   | SSP 30237 Rev. F CE01 | Compliance  |
| Conducted Emissions, DC Power Leads, 10 kHz - 50 MHz               | SSP 30237 Rev. F CE02 | Compliance  |
| Conducted Emissions, DC Power Leads, Switching Spikes, Time Domain | SSP 30237 Rev. F CE07 | Compliance  |
| Conducted Susceptibility, AC Power Leads, 30 Hz - 50 kHz           | SSP 30237 Rev. F CS01 | Compliance  |
| Conducted Susceptibility, AC Power Leads, 50 kHz - 50 MHz          | SSP 30237 Rev. F CS02 | Compliance  |
| Conducted Susceptibility, Spikes, DC Power Leads                   | SSP 30237 Rev. F CS06 | Compliance  |
| Radiated Emissions, Electric Field, 14 kHz - 20 GHz                | SSP 30237 Rev. F RE02 | Compliance  |
| Radiated Susceptibility, Magnetic Induction Field                  | SSP 30237 Rev. F RS02 | Compliance  |
| Radiated Susceptibility, Electric Field, 10 kHz - 18 GHz           | SSP 30237 Rev. F RS03 | Compliance  |

*Left intentionally blank*

Terni, 19 April 2006.

Test Report issued by:  
Ing. Antonio Faba

Approved by:  
Prof. Ing. Ermanno Cardelli




Polo Scientifico e Didattico di Terni - Facoltà di Ingegneria  
Via Pentima Bassa 21, 05100 Terni - Tel. +39 0744/492912 - Fax. +39 0744/492925

Pag.23 di 23

B. Borgia  
TIM April 2006

# Vibration test



Cards always on during vibration cycles

Functionality test  
before/after OK.

*B. Borgia  
TIM April 2006*

**No failures**

# Electronics production schedule

- UGPS-FM ready to go to production
  - UGPS-FM acceptance test
    - 1st week June
  - {UGBS/UGBC/UGFV}-QM qualification
    - last week June
  - {UGBS/UGBC/UGFV}-FM acceptance
    - July 15th
- ⇒ all UG electronics ready by November 2006

*upon availability of Terni Laboratory*

# **TRD GAS SYSTEM STATUS**

Francesca Bucci, Francesca Spada



Roma, 13-3-06

# Summing up

- EM Box S:
  - Heaters tested for both Xe and CO<sub>2</sub>;
  - Mixing cycles successfully executed under computer control;
  - Emergency procedure tried:
    - Ar through CO<sub>2</sub> line opening V1a, V20a&V20b, V2b, V3b: too little gas transferred to D vessel → buffers too small;
    - CO<sub>2</sub> through Xe line opening V1b, V20a&V20b, V2a, V3a: controllable;
  - Pressure sensors noise eliminated with rewiring.
  - *Dallas temperature sensors calibrated with Pt thermometers*


- EM Box C:
  - All components tested and operated successfully under computer control;
  - MCA calibrated;
  - Preamplifier connected and tested;
  - Monitor tubes connected and tested.
- EM Electronics:
  - 2 USCMs plugged in;
  - UHVG connected and tested.

- MCA calibration for input range [0,10] V




- $^{55}\text{Fe}$  spectra:


- Tube 1, amp ch 1: cut on ADC channels  $\leq 60$



Fe spectrum. Tube # 1, Amp ch 1, HV: 1275 V




Fe spectrum. Tube # 1, Amp ch 1, HV: 1300 V




All spectra fitted using an exp function for background + two gaussian functions

Fe spectrum. Tube # 1, Amp ch 1, HV: 1325 V



Fe spectrum. Tube # 1, Amp ch 1, HV: 1350 V



- EM Electronics:

- UHVG working properly:

- HV up to 1800 V;

- USCMs, UGBSs, UGBCs hot & cold tested:

- Each module working properly in hot or cold mode;
    - No conflicts between board while using any combination of USCM hot or cold with UGBS, UGBC hot or cold;

- **A note on the test results is available at**

- <http://www.cern.ch/spada/AMS/IntegratedTestReport.ps.gz>**

---


# **Status Report on Software Interface with TRD GAS Control Electronics WINCAN**

**F. Spada/Rome**


Code and Manual available at:  
<http://www.cern.ch/spada/AMS/>

F. Spada - AMS TIM April '06

# Evolution of the gas system control for flight



## ISS <-> ground data communication - software location



## Security checks

- Security conditions to be verified before operating on the system
  - *On valves:*
    - **Prevent** opening a valve if the last temperature readout is too old or if temperature is under a fixed threshold
    - Before opening a valve on the tank - D vessel line, **disable** the upstream one (avoid two valves open at a time)
  - *On heaters*
    - **No heater** on **if** a Marotta valve is open (not enough power)
    - **Prevent** opening a valve if a heater is on (not enough power)
- These conditions are automatically taken into account in following commands and procedures.

# Defined states of the gas system/1

To minimize the communication with space:


- define states of the system - the definition resides on the JMDC
- from ground only send command "bring system in status x"

## *Examples of defined states:*


|                |                                                                                                                                                     |
|----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| state "Ground" |                                                                                                                                                     |
| box S          | <ul style="list-style-type: none"><li>• Disable all Marotta</li><li>• Heaters off</li></ul>                                                         |
| box C          | <ul style="list-style-type: none"><li>• Disable all Marotta</li><li>• Close V8</li><li>• Pumps off</li><li>• HV off</li><li>• Heaters off</li></ul> |
| manifold       | <ul style="list-style-type: none"><li>• Close all VA, VB, VC, VD</li></ul>                                                                          |

## Defined states of the gas system/2


state "Empty"



## Defined states of the gas system/3




## Defined states of the gas system/4




## Diagnostic procedures/1


Example of a procedure to determine the status of electromechanical components: check of the Marotta valves in the box S after a dysfunctional behaviour of the pressure in the D vessel.




## Diagnostic procedures/2



## Diagnostic procedures/3



## Diagnostic procedures/4



## Summary

---

- WINCAN split in four branches
  - Basic
  - Monitor
  - Macro
  - Diagnostic
- Security conditions included
- Defined states of the system

### To do:

- Continue with safety study
- Define operational procedure
- More diagnostic procedures
- Develop monitor
- ...

# Summary

- Gas control electronics is in qualification and production line
- Gas circuit is extensively tested but needs better understanding of procedures
- Software commands needs in deep analysis mainly for safety

# Progress On TRD Gas System

**AMS TIM at CERN**

**April 22, 2006**

# Flight Module - Added components


## Pre-heater

- Control amount of CO<sub>2</sub>/Xe transfer
- Comparable EM/QM tests & thermal model results

## Back-flow Valves

- Provision for excess pressure trapped in 1<sup>st</sup> buffer vol. → storage vessel

# Box S Additions: a) backflow valves. b) Pre-heaters



April 24

Martina Green



# **Flight Module - Components**

- **Heaters - in hand**
- **Thermostats - in hand**
- **Preheater-Vol - at Arde**
- **Back Flow Valves - received**

# Flight Module – Progress

## Vessel fill - CO<sub>2</sub>/Xe (Linde)

- Procedures in progress
- Vessel DOT exemption: Xe – from previous exemption  
CO<sub>2</sub> – further inquiry by Arde
- Fill location: TBD (Ohio / KSC?)
- Back-flow Valve
  - Housing design (The Lee Co)
- Wire Soldering
  - To be performed by MIT Space Center (space qualified)

# FM Box S - Arde's revised schedule

- Complete all subassemblies (~May 5/06)
- System assembly (~May 15/06 – June 16/06)
- System Test (June 26 - 30/06)
- Ship to MIT (July/06)